



December 3, 2025

City of St. Cloud  
Building Department  
1300 9<sup>th</sup> Street, Bldg. A, 1<sup>st</sup> Floor  
St. Cloud, FL 34769  
(407) 957-7224

<b>Re:</b>	<b>Permit Number:</b>	<b>B25-00005425</b>
	<b>Project Name:</b>	<b>Chipotle Shell</b>
	<b>Address:</b>	<b>2000 Nolte Road</b>
	<b>Project Location:</b>	<b>St. Cloud, FL</b>
	<b>FWH Project No.:</b>	<b>25008</b>

The following letter is a narrative of plan changes that have occurred to the construction drawings but have not been implemented into the building permit stated above. These plan changes occurred after the Contractor pulled the permit and this submission is to bring the permit up to date with the City's files. All modifications have been clouded and tagged with **Delta No. 2, dated 12.02.25, Revised per coordination with tenant interiors**. Below is a summary of the changes.

**ARCHITECTURAL:**

**Sheet G000**

- The project address was added to this Sheet.
- The Drawing Index was updated for Revision Two.

**Sheet G013**

- The specifications were updated based on tenant comments.

**Sheet G014**

- The specifications were updated based on tenant comments.

**Sheet SP100**

- The site lighting was updated to match electrical plans.

- Pavement graphics and bike rack location were updated to match tenant plans.

#### **Sheet A100**

- Door Three was relocated to match tenant plans.
- Label D1 was added to the storefront adjacent to the drive-thru bump.

#### **Sheet A140**

- Future roof equipment was updated to match tenant plans.

#### **Sheet A300**

- The door handle on the east façade was omitted.

#### **Sheet A301**

- The north façade was updated for plan changes and tenant comments.
- The storefront glass on one opening on the west façade and rear door was revised to spandrel.

#### **Sheet A400**

- The grid dimensions on Sections One and Two were corrected.

#### **Sheet A404**

- Break metal was eliminated from interior of Detail One.

#### **Sheet A602**

- Notes were added to call for spandrel glass in some locations.
- Storefront D1 was added.

#### **STRUCUTRAL:**

#### **Sheet S100**

- Revised the location of a rear masonry wall opening.

#### **Sheet S200**

- Updated tenant mechanical equipment locations and weights.

#### **PLUMBING:**

#### **Sheet P200**

- Grease interceptor vent line rerouted to match tenant plans.
- VTR relocated per Arch plans.
- Roof hydrant relocated per tenant plans.
- Grease interceptor size revised to match tenant plans.
- Grease line exists were adjusted to match updated civil.

**Sheet P300**

- Grease interceptor vent line rerouted to match tenant plans.
- Grease interceptor size revised to match tenant plans.
- Grease line exits were adjusted on riser to match updated civil.

**ELECTRICAL:****Sheet E100**

- Revised (1) site pole from 'SB' to 'CD' to comply with lighting levels and/or around dumpster and walkway.
- Revised Fixture Schedule.

**Sheet E101**

- Photometrics revised to comply with lighting levels and/or around dumpster and walkway.
- Revised (1) site pole from 'SB' to 'CD' to comply with lighting levels and/or around dumpster and walkway.

**Sheet E102**

- Added specification sheet for new fixture type 'CD'.

**Sheet E200**

- Replaced background.
- Coordinated j-boxes for building signage to match TI plans.

**Sheet E300**

- Removed reference to any aluminum conductors per electrical plan review.

If you have any questions regarding the above or have further comments, please do not hesitate to call.

Sincerely,

Guy F. Faber, President  
FWH Architects, Inc.  
FL License No. AR0015323